CENTRAL POWER RESEARCH INSTITUTE (Member of STL)



TEST REPORT

CPRIBLRSCL19T0482 Date: 27 August 2019 **Test Report Number**

Name & Address of the Customer M/s. Shrivaari Electricals Pvt. Ltd., C-37, T. V. K. Industrial Estate,

Guindy, Chennai - 600 032,

Tamil Nadu, India.

Name & Address of the Manufacturer M/s. Shrivaari Electricals Pvt. Ltd.,

C-37, T. V. K. Industrial Estate, Guindy, Chennai - 600 032,

Tamil Nadu, India.

Particulars of sample tested 440V, 400A LT panel

Condition of the sample on Receipt

Indoor Type

Description of sample 440V, 400A LT panel

Serial Number (s) SVE/LT/002

Number of samples tested One

Date (s) of test (s) 10 & 11 June, 2019 CPRI sample code no(s). SCL19S0533

Particulars of tests conducted 1) Marking

2) Mechanical impact

3) Lifting

4) Clearances and creepage distances

Test in accordance with

Standard / specification Sub-clause 10.2.7, 10.2.6, 10.2.5 & 10.4 of

IEC 61439-1: 2011-08

Sampling plan Not applicable

Customer's requirement Nil Deviations if any Nil

Name of the witnessing persons

Mr. B. Jagan Mohan, G.M - Operations Customer's representative

Other than customer's representatives None

Test subcontracted with

address of the laboratory None

Documents constituting this report (In words)

Number of sheets Seven Number of oscillograms Nil Number of graphs Nil Nil Number of photos Number of test circuit diagrams Nil

Number of drawings Three

Arjuna Rao) **Test Engineer**

(Swarai Kumar Das) **Head of Division** Approved by

ULR-TC5452190SCLT0482F

Discipline: Electrical Testing Group: Switchgear & Protective

Equipment

SHORT CIRCUIT LABORATORY

P.B.NO.8066, SADASHIVANAGAR POST OFFICE SIR C.V.RAMAN ROAD, BENGALURU - 560 080 (INDIA)

Phone: +91 (0) 80 - 22072353 Fax: +91 (0) 80 - 23601213

Sheet 1 of 7

CENTRAL POWER RESEARCH INSTITUTE (Member of STL)



TEST REPORT

Test Report Number: CPRIBLRSCL19T0482

Date: 27 August 2019

DESCRIPTION OF SAMPLE TESTED

(As assigned by the manufacturer)

Test LT Panel Type Indoor

Serial number SVE/LT/002

Rated voltage 440 V Rated insulation voltage 660 V Rated impulse with stand voltage U_{imp} 8 kV

Rated current 400 A Rated frequency 50 Hz

Number of phases Three & Neutral

IK Code10Pollution degree1Material groupI

(S. Arjuna Rao) Test Engineer